

# Chapter 33 Fire Safety During Construction and Demolition

## CALIFORNIA FIRE CODE — MATRIX ADOPTION TABLE CHAPTER 33 — FIRE SAFETY DURING CONSTRUCTION AND DEMOLITION

(Matrix Adoption Tables are nonregulatory, intended only as an aid to the code user.  
See Chapter 1 for state agency authority and building applications.)

Adopting Agency	BSC	BSC- CG	SFM		HCD			DSA		OSHPD					BSCC	DPH	AGR	DWR	CEC	CA	SL	SLC
			T- 24	T- 19*	1	2	1/AC	AC	SS	1	1R	2	3	4	5							
Adopt Entire Chapter		X																				
Adopt Entire Chapter as amended (amended sections listed below)																						
Adopt only those sections that are listed below																						
[California Code of Regulations, Title 19, Division 1]																						
Chapter / Section																						
3308.9		X																				

\* The *California Code of Regulations* (CCR), Title 19, Division 1 provisions that are found in the *California Fire Code* are a reprint from the current CCR, Title 19, Division 1 text for the code user's convenience only. The scope, applicability and appeals procedures of CCR, Title 19, Division 1 remain the same.

### User note:

**About this chapter:** Chapter 33 outlines general fire safety precautions for all structures and all occupancies during construction and demolition operations. In general, these requirements seek to maintain required levels of fire protection, limit fire spread, establish the appropriate operation of equipment and promote prompt response to fire emergencies. Features regulated include fire protection systems, fire fighter access to the site and building, means of egress, hazardous materials storage and use, and temporary heating equipment and other ignition sources. Fire watches are an important component of this chapter. This chapter correlates with Chapter 33 of the International Building Code®.

### Section 3301 General

#### 3301.1 Scope

This chapter shall apply to structures in the course of construction, alteration or demolition, including those in underground locations. Compliance with NFPA 241 is required for items not specifically addressed herein.

### **3301.2 Purpose**

This chapter prescribes minimum safeguards for construction, alteration and demolition operations to provide reasonable safety to life and property from fire during such operations.

## **Section 3302 Definitions**

### **3302.1 Terms Defined in Chapter 2**

Words and terms used in this chapter and defined in Chapter 2 shall have the meanings ascribed to them as defined therein.

## **Section 3303 Temporary Heating Equipment**

### **3303.1 Listed**

Temporary heating devices shall be listed and labeled. The installation, maintenance and use of temporary heating devices shall be in accordance with the listing and the manufacturer's instructions.

### **3303.2 Oil-Fired Heaters**

Oil-fired heaters shall comply with Section 603.

### **3303.3 LP-gas Heaters**

Fuel supplies for liquefied-petroleum gas-fired heaters shall comply with Chapter 61 and the *California Mechanical Code*.

### **3303.4 Refueling**

Refueling operations for liquid-fueled equipment or appliances shall be conducted in accordance with Section 5705. The equipment or appliance shall be allowed to cool prior to refueling.

### **3303.5 Installation**

Clearance to combustibles from temporary heating devices shall be maintained in accordance with the labeled equipment. When in operation, temporary heating devices shall be fixed in place and protected from damage, dislodgement or overturning in accordance with the manufacturer's instructions.

### **3303.6 Supervision**

The use of temporary heating devices shall be supervised and maintained only by competent personnel.

**Section 3304 Precautions Against Fire****3304.1 Smoking**

Smoking shall be prohibited except in approved areas. Signs shall be posted in accordance with Section 310. In approved areas where smoking is permitted, approved ashtrays shall be provided in accordance with Section 310.

**3304.2 Combustible Debris, Rubbish and Waste**

Combustible debris, rubbish and waste material shall comply with the requirements of Sections 3304.2.1 through 3304.2.4.

**3304.2.1 Combustible Waste Material Accumulation**

Combustible debris, rubbish and waste material shall not be accumulated within buildings.

**3304.2.2 Combustible Waste Material Removal**

Combustible debris, rubbish and waste material shall be removed from buildings at the end of each shift of work.

**3304.2.3 Rubbish Containers**

Where rubbish containers with a capacity exceeding 5.33 cubic feet (40 gallons) ( $0.15 \text{ m}^3$ ) are used for temporary storage of combustible debris, rubbish and waste material, they shall have tight-fitting or self-closing lids. Such rubbish containers shall be constructed entirely of materials that comply with either of the following:

1. Noncombustible materials.
2. Materials that meet a peak rate of heat release not exceeding  $300 \text{ kW/m}^2$  when tested in accordance with ASTM E1354 at an incident heat flux of  $50 \text{ kW/m}^2$  in the horizontal orientation.

**3304.2.4 Spontaneous Ignition**

Materials susceptible to spontaneous ignition, such as oily rags, shall be stored in a listed disposal container.

**3304.3 Burning of Combustible Debris, Rubbish and Waste**

Combustible debris, rubbish and waste material shall not be disposed of by burning on the site unless approved.

**3304.4 Open Burning**

Open burning shall comply with Section 307.

**3304.5 Fire Watch**

Where required by the fire code official or the prefire plan established in accordance with Section 3308.3, a fire watch shall be provided for building demolition and for building construction that is hazardous in nature, such as temporary heating or hot work.

#### **3304.5.1 Fire Watch During Construction**

Where required by the fire code official, a fire watch shall be provided during nonworking hours for new construction that exceeds 40 feet (12 192 mm) in height above the lowest adjacent grade.

#### **3304.5.2 Fire Watch Personnel**

Trained personnel shall be provided to serve as an on-site fire watch. Fire watch personnel shall be provided with not fewer than one approved means for notification of the fire department, and the sole duty of such personnel shall be to perform constant patrols and watch for the occurrence of fire. The combination of fire watch duties and site security duties is acceptable. Fire watch personnel shall be trained in the use of portable fire extinguishers.

#### **3304.5.3 Fire Watch Location and Records**

The fire watch shall include areas specified by the prefire plan established in accordance with Section 3308.3. The fire watch personnel shall keep a record of all time periods of duty, including a log entry each time the site was patrolled and each time a structure under construction was entered and inspected. The records and log entries shall be made available for review by the fire code official upon request.

#### **3304.6 Cutting and Welding**

Welding, cutting, open torches and other hot work operations and equipment shall comply with Chapter 35.

#### **3304.7 Electrical**

Temporary wiring for electrical power and lighting installations used in connection with the construction, alteration or demolition of buildings, structures, equipment or similar activities shall comply with *the California Electrical Code*.

#### **3304.8 Cooking**

Cooking shall be prohibited except in approved designated cooking areas. Signs with a minimum letter height of 3 inches (76 mm) and a minimum brush stroke of  $\frac{1}{2}$  inch (13 mm) shall be posted in conspicuous locations in designated cooking areas and state:

DESIGNATED COOKING AREA  
COOKING OUTSIDE OF A DESIGNATED COOKING  
AREA IS PROHIBITED

### **Section 3305 Flammable and Combustible Liquids**

#### **3305.1 Storage of Flammable and Combustible Liquids**

Storage of flammable and combustible liquids shall be in accordance with Section 5704.

**3305.2 Class I and Class II Liquids**

The storage, use and handling of flammable and combustible liquids at construction sites shall be in accordance with Section 5706.2. Ventilation shall be provided for operations involving the application of materials containing flammable solvents.

**3305.3 Housekeeping**

Flammable and combustible liquid storage areas shall be maintained clear of combustible vegetation and waste materials. Such storage areas shall not be used for the storage of combustible materials.

**3305.4 Precautions Against Fire**

Sources of ignition and smoking shall be prohibited in flammable and combustible liquid storage areas. Signs shall be posted in accordance with Section 310.

**3305.5 Handling at Point of Final Use**

Class I and II liquids shall be kept in approved safety containers.

**3305.6 Leakage and Spills**

Leaking vessels shall be immediately repaired or taken out of service and spills shall be cleaned up and disposed of properly.

**Section 3306 Flammable Gases****3306.1 Storage and Handling**

The storage, use and handling of flammable gases shall comply with Chapter 58.

**3306.2 Cleaning With Flammable Gas**

Flammable gases shall not be used to clean or remove debris from piping open to the atmosphere.

**3306.2.1 Pipe Cleaning and Purging**

The cleaning and purging of flammable gas piping systems, including cleaning new or existing piping systems, purging piping systems into service and purging piping systems out of service, shall comply with NFPA 56.

**Exceptions:**

1. Compressed gas piping systems other than fuel gas piping systems where in accordance with Chapter 53.
2. Piping systems regulated by the *International Fuel Gas Code*.
3. Liquefied petroleum gas systems in accordance with Chapter 61.

**Section 3307 Explosive Materials****3307.1 Storage and Handling**

Explosive materials shall be stored, used and handled in accordance with Chapter 56.

**3307.2 Supervision**

Blasting operations shall be conducted in accordance with Chapter 56.

**3307.3 Demolition Using Explosives**

Approved fire hoses for use by demolition personnel shall be maintained at the demolition site wherever explosives are used for demolition. Such fire hoses shall be connected to an approved water supply and shall be capable of being brought to bear on post-detonation fires anywhere on the site of the demolition operation.

**Section 3308 Owner's Responsibility for Fire Protection****3308.1 Program Development and Maintenance**

The owner or owner's authorized agent shall be responsible for the development, implementation and maintenance of a written plan establishing a fire prevention program at the project site applicable throughout all phases of the construction, repair, alteration or demolition work. The plan shall address the requirements of this chapter and other applicable portions of this code, the duties of staff, and staff training requirements. The plan shall be made available for review by the fire code official upon request.

**3308.2 Program Superintendent**

The owner shall designate a person to be the fire prevention program superintendent who shall be responsible for the fire prevention program and ensure that it is carried out through completion of the project. The fire prevention program superintendent shall have the authority to enforce the provisions of this chapter and other provisions as necessary to secure the intent of this chapter. Where guard service is provided in accordance with NFPA 241, the superintendent shall be responsible for the guard service.

**3308.3 Prefire Plans**

The fire prevention program superintendent shall develop and maintain an approved prefire plan in cooperation with the fire chief. The fire chief and the fire code official shall be notified of changes affecting the utilization of information contained in such prefire plans.

**3308.4 Training**

Training of responsible personnel in the use of fire protection equipment shall be the responsibility of the fire prevention program superintendent. Records of training shall be kept and made a part of the written plan for the fire prevention program.

**3308.5 Fire Protection Devices**

The fire prevention program superintendent shall determine that all fire protection equipment is maintained and serviced in accordance with this code. The quantity and type of fire protection equipment shall be *approved*. Fire protection equipment shall be inspected in accordance with the fire protection program.

### **3308.6 Hot Work Operations**

The fire prevention program superintendent shall be responsible for supervising the permit system for hot work operations in accordance with Chapter 35.

### **3308.7 Impairment of Fire Protection Systems**

Impairments to any fire protection system shall be in accordance with Section 901.

#### **3308.7.1 Smoke Detectors and Smoke Alarms**

Smoke detectors and smoke alarms located in an area where airborne construction dust is expected shall be covered to prevent exposure to dust or shall be temporarily removed. Smoke detectors and alarms that were removed shall be replaced upon conclusion of dust-producing work. Smoke detectors and smoke alarms that were covered shall be inspected and cleaned, as necessary, upon conclusion of dust-producing work.

### **3308.8 Temporary Covering of Fire Protection Devices**

Coverings placed on or over fire protection devices to protect them from damage during construction processes shall be immediately removed upon the completion of the construction processes in the room or area in which the devices are installed.

### **3308.9 Fire Safety Requirements for Buildings of Types IVA, IV-B, and IV-C Construction**

*Buildings of Types IV-A, IV-B, and IV-C construction designed to be greater than 6 stories above grade plane shall comply with the following requirements during construction unless otherwise approved by the fire code official.*

1. *Standpipes shall be provided in accordance with Section 3313.*
2. *A water supply for fire department operations, as approved by the fire code official and the fire chief.*
3. *Where building construction exceeds 6 stories above grade plane, at least one layer of noncombustible protection where required by Section 602.4 of the California Building Code shall be installed on all building elements more than 4 floor levels, including mezzanines, below active mass timber construction before erecting additional floor levels.*

***Exception:*** *Shafts and vertical exit enclosures shall not be considered a part of the active mass timber construction.*

4. *Where building construction exceeds 6 stories above grade plane required exterior wall coverings shall be installed on all floor levels more than 4 floor levels, including mezzanines, below active mass timber construction before erecting additional floor level.*

***Exception:*** *Shafts and vertical exit enclosures shall not be considered a part of the active mass timber construction.*

## Section 3309 Fire Reporting

### 3309.1 Emergency Telephone

Emergency telephone facilities with ready access shall be provided in an approved location at the construction site, or an approved equivalent means of communication shall be provided. The street address of the construction site and the emergency telephone number of the fire department shall be posted adjacent to the telephone. Alternatively, where an equivalent means of communication has been approved, the site address and fire department emergency telephone number shall be posted at the main entrance to the site, in guard shacks and in the construction site office.

## Section 3310 Access for Fire Fighting

### 3310.1 Required Access

Approved vehicle access for fire fighting shall be provided to all construction or demolition sites. Vehicle access shall be provided to within 100 feet (30 480 mm) of temporary or permanent fire department connections. Vehicle access shall be provided by either temporary or permanent roads, capable of supporting vehicle loading under all weather conditions. Vehicle access shall be maintained until permanent fire apparatus access roads are available.

### 3310.2 Key Boxes

Key boxes shall be provided as required by Chapter 5.

## Section 3311 Means of Egress

### [BE] 3311.1 Stairways Required

Where building construction exceeds 40 feet (12 192 mm) in height above the lowest level of fire department vehicle access, a temporary or permanent stairway shall be provided. As construction progresses, such stairway shall be extended to within one floor of the highest point of construction having secured decking or flooring.

### 3311.2 Maintenance

Required means of egress and required accessible means of egress shall be maintained during construction and demolition, remodeling or alterations and additions to any building.

**Exception:** Approved temporary means of egress and accessible means of egress systems and facilities.

## Section 3312 Water Supply for Fire Protection

### 3312.1 When Required

An approved water supply for fire protection, either temporary or permanent, shall be made available as soon as combustible material arrives on the site.

## Section 3313 Standpipes

**3313.1 Where Required**

In buildings required to have standpipes by Section 905.3.1, not less than one standpipe shall be provided for use during construction. Such standpipes shall be installed prior to construction exceeding 40 feet (12 192 mm) in height above the lowest level of fire department vehicle access. Such standpipes shall be provided with fire department hose connections at locations adjacent to stairways complying with Section 3311.1. As construction progresses, such standpipes shall be extended to within one floor of the highest point of construction having secured decking or flooring.

**3313.2 Buildings Being Demolished**

Where a building is being demolished and a standpipe is existing within such a building, such standpipe shall be maintained in an operable condition so as to be available for use by the fire department. Such standpipe shall be demolished with the building but shall not be demolished more than one floor below the floor being demolished.

**3313.3 Detailed Requirements**

Standpipes shall be installed in accordance with the provisions of Section 905.

**Exception:** Standpipes shall be either temporary or permanent in nature, and with or without a water supply, provided that such standpipes comply with the requirements of Section 905 as to capacity, outlets and materials.

**Section 3314 Automatic Sprinkler System****3314.1 Completion Before Occupancy**

In buildings where an automatic sprinkler system is required by this code or the *California Building Code*, it shall be unlawful to occupy any portion of a building or structure until the automatic sprinkler system installation has been tested and approved, except as provided in Section 105.3.4.

**3314.2 Operation of Valves**

Operation of sprinkler control valves shall be allowed only by properly authorized personnel and shall be accompanied by notification of duly designated parties. Where the sprinkler protection is being regularly turned off and on to facilitate connection of newly completed segments, the sprinkler control valves shall be checked at the end of each work period to ascertain that protection is in service.

**Section 3315 Portable Fire Extinguishers****3315.1 Where Required**

Structures under construction, alteration or demolition shall be provided with not less than one approved portable fire extinguisher in accordance with Section 906 and sized for not less than ordinary hazard as follows:

1. At each stairway on all floor levels where combustible materials have accumulated.
2. In every storage and construction shed.

3. Additional portable fire extinguishers shall be provided where special hazards exist including, but not limited to, the storage and use of flammable and combustible liquids.

## **Section 3316 Motorized Construction Equipment**

### **3316.1 Conditions of Use**

Internal-combustion-powered construction equipment shall be used in accordance with all of the following conditions:

1. Equipment shall be located so that exhausts do not discharge against combustible material.
2. Exhausts shall be piped to the outside of the building.
3. Equipment shall not be refueled while in operation.
4. Fuel for equipment shall be stored in an approved area outside of the building.

## **Section 3317 Safeguarding Roofing Operations**

### **3317.1 General**

Roofing operations utilizing heat-producing systems or other ignition sources shall be conducted in accordance with Sections 3317.2 and 3317.3 and Chapter 35.

### **3317.2 Asphalt and Tar Kettles**

Asphalt and tar kettles shall be operated in accordance with Section 303.

### **3317.3 Fire Extinguishers for Roofing Operations**

Fire extinguishers shall comply with Section 906. There shall be not less than one multiple-purpose portable fire extinguisher with a minimum 3-A 40-B:C rating on the roof being covered or repaired.

**State of California**

**PUBLIC RESOURCES CODE**

**Section 4442**

---

4442. (a) Except as otherwise provided in this section, no person shall use, operate, or allow to be used or operated, any internal combustion engine which uses hydrocarbon fuels on any forest-covered land, brush-covered land, or grass-covered land unless the engine is equipped with a spark arrester, as defined in subdivision (c), maintained in effective working order or the engine is constructed, equipped, and maintained for the prevention of fire pursuant to Section 4443.

(b) Spark arresters affixed to the exhaust system of engines or vehicles subject to this section shall not be placed or mounted in such a manner as to allow flames or heat from the exhaust system to ignite any flammable material.

(c) A spark arrester is a device constructed of nonflammable materials specifically for the purpose of removing and retaining carbon and other flammable particles over 0.0232 of an inch in size from the exhaust flow of an internal combustion engine that uses hydrocarbon fuels or which is qualified and rated by the United States Forest Service.

(d) Engines used to provide motive power for trucks, truck tractors, buses, and passenger vehicles, except motorcycles, are not subject to this section if the exhaust system is equipped with a muffler as defined in the Vehicle Code.

(e) Turbocharged engines are not subject to this section if all exhausted gases pass through the rotating turbine wheel, there is no exhaust bypass to the atmosphere, and the turbocharger is in effective mechanical condition.

(f) Motor vehicles when being operated in an organized racing or competitive event upon a closed course are not subject to this section if the event is conducted under the auspices of a recognized sanctioning body and by permit issued by the fire protection authority having jurisdiction.

(Amended by Stats. 1982, Ch. 1333, Sec. 18.)